

BID DOCUMENTS FOR
WSCC GENDER NEUTRAL WASHROOMS

15 June 2022
FILE: 144903195

ISSUED BY: _____

Maggie Burt, Intern Architect
Stantec Architecture Ltd.
Tel: (867)-920-2882 ext.258
Fax:
maggie.burt@stantec.com

Addendum issued to active tenderers with documents on record **(1 pages including attachments)**

1. Questions

- 1.1. As per the response in 2.4.1 Stating to confirm that the use of CPVC Blazemaster is acceptable with the local AHJ. This creates an issue. I have chatted with the OFM on this topic in the past and as long as we use any ULc or FM approved for sprinkler system product in sprinkler systems, it will be acceptable by the OFM. Blazemaster is already an approved product and in this case has already been accepted and installed on three floors of this building. We believe the note of 2.4.1 should be changed before we can quote this project to make sure we are all on the same page.

1.1.1.Response: The use of CPVC Blazemaster is acceptable.

End of Addendum